

From: [Lee Ellmaker](#)
To: [Moore, Gary](#)
Cc: [Sean Gavlas](#)
Subject: Re: FJ Doyle Building
Date: Thursday, October 11, 2018 5:28:11 PM
Attachments: [image001.png](#)
[ARC009.pdf](#)

Hi Gary,

I attached a State of Texas document for clarification on demolition of asbestos in place. Although this is not a public access building it would be classified as one because it is not secured and enclosed by a fence.

Regards,

Lee Ellmaker, P.E. | Engineer | MEC^X

Mobile: 775.771.8419

Office: 713.585.7000 x 7009

Fax: 713.585.7049



8864 Interchange Drive | Houston, Texas 77054

A Service-Disabled Veteran-Owned Small Business

lee.ellmaker@mecx.net | <http://www.mecx.net>

This communication is intended solely for the benefit of the intended addressee(s). It may contain privileged and/or confidential information. If this message is received in error by anyone other than the intended recipient(s), please delete this communication from all records and advise the sender via electronic mail of the deletion.

From: Lee Ellmaker <lee.ellmaker@mecx.net>
Date: Thursday, October 11, 2018 at 8:13 AM
To: "Moore, Gary" <Moore.Gary@epa.gov>
Cc: Sean Gavlas <Sean.Gavlas@WestonSolutions.com>
Subject: Re: FJ Doyle Building

Hi Gary,

Because the asbestos present is category 1 non-friable roofing you can use standard contractor and can dispose of as general waste. During roof removal I would follow general safe practices for dust suppression and worker safety. I would also let the contractor and landfill know there is some non-regulated asbestos roofing sealant present. We can have a call if you would like to go over in more detail.

lee ellmaker, p.e. | engineer | mecx

mobile [775.771.8419](tel:775.771.8419)
fax [713.585.7049](tel:713.585.7049)
office [713.585.7000](tel:713.585.7000) x 7009
[8864 interchange drive](http://8864interchange.com)
[houston, texas](http://houston.texas) 77054
lee.ellmaker@mecx.net

On Oct 10, 2018, at 9:09 PM, Moore, Gary <Moore.Gary@epa.gov> wrote:

Hey Lee,

Based upon your report, do we need an asbestos certified contractor to remove the metal roof from the building?

Also, will the roof need to be disposed as asbestos debris?

How should this happen?

Thanks
Gary Moore
2147891627

Sent from my iPhone